

# Generator Monitoring Plans

WRIG feedback changes

# Major feedback I

- Mandatory tests in Appendix B
  - Frequency of testing => frequency of evidence of compliance
    - Frequency at which evidence of compliance is obtained from either mandatory testing and/or other monitoring mechanisms;
    - Clarification: Suggested frequency; Market Participants to propose, in accordance with required principles and factors
  - Rated Maximum Active Power => maximum Active Power specified in the Registered Generator Performance Standard
  - Specified Maximum ambient temperature => where practicable and must show intention to do so
  - Operating conditions => Operating arrangements with Generating System
- Other clarifications:
  - No requirements for all machines to be tested in the same year
  - Requirements for recording device are set out under 'Testing and Monitoring Regime'

# Major feedback II

- Generator Monitoring Plans
  - Changes to an approved Generator Monitoring Plan
    - Notify AEMO as soon as practically possible, submit revision within 20 Business Days
  - Clarification: Approved Generator Monitoring Plan remains in effect until superseded
- Non-compliance
  - Suspected (observation), to be verified by tests until reasonably conclusive
- Mechanisms by which notifications and submissions are made: MPI & Email
- Records to be retained
  - All correspondences => all written correspondences
  - Retention of records – 10.1.2(d) consistent with all market information



# Other changes

- New AEMO introduction template
  - Consistent use of
    - “paragraph” for intra-Procedure references
    - “clause” for WEM Rule references
- Editorial changes
- Clarifications where needed
  
- Contact: [WA.ETS@aemo.com.au](mailto:WA.ETS@aemo.com.au)