

# WEM Procedure: Facility Sub-Metering

Post-consultation changes

# Procedure amendments

- AEMO received several submission to request AEMO review a Facility Sub-Metering arrangement prior to the initial audit, to ensure the proposed arrangement will be accepted.
  - AEMO does not have a HoP to undertake an audit prior to the initial audit, but would provide informal advice to Market Participants on any proposed arrangement. This would not constitute any confirmation that the final installation fully met the requirements of the Procedure.

# Other comments and AEMO's response

Summary of comment	AEMO's response
Recommendation to use Metering Code Definition of Interval Energy Data	AEMO has considered this option but recommends alignment with the NER Definition
Recommendation paragraph 2.1.1 is amended for clarity, to specify parasitic (auxiliary loads) must be associated with each Separately Certified Component	Paragraph amended
Recommendation paragraph 2.1.7 is expanded to specify relevant data capture	Paragraph amended to include Active/Reactive for Import/Export
Recommendation paragraph 2.1.9 is expanded to specify (calendar/Capacity year), also recommend this only applies to Facilities with components certified under the RLM	AEMO has amended the clause to refer explicitly to the Relevant Level Methodology.
Recommend the consolidation into a single audit process for both Initial Audit and Subsequent Audits of Facility Sub-Metering	AEMO has retained the two sections to ensure that the relative differences in audit requirements are clear to Market Participants
Recommended changes to Paragraph 4.1.3 for clarity	Paragraph amended
4.1.5 include "reasonably required"	Paragraph amended
4.1.9 should include reasons for AEMO's decision to consider a Facility has not verified its Facility Sub-Metering meets the requirements of the Procedure.	Additional Paragraph 4.1.8 added to include reasons.
4.1.3 / 4.2.1 Timing of audits and reporting, Market Participants felt that both the timing for audit and the report should be subject to a reasonably determined timeframe	Paragraph amended
4.4.4 Recommendation paragraph 4.4.4 includes an ability to submit details of rectification to avoid subsequent audit	Paragraph amended